

To: All Prospective Bidders

Date: April 4, 2023

Subject: Addendum # 5 - ITB # FY23-ITB-08 - WWTP Polymers

Please note the specification changes/modifications below for the ITB.

Item #	Page #	Section #	Specification	Modifications and Questions	
Item #	Page #	Section #	Addendum No. 4	Modifications at Clarification: The previous addendum WWTP's Pass/Fail Criteria. modified per Addendum No WWTP, as accurately depicted. The McDowell Mallard Creek WSolids Dewatering Polymer w Addendum No. 4:  Mallard Creek WWTF Solids Dewatering Polymer	referenced the wrong The Pass/Fail Criteria b. 4 is for Mallard Creek ed below.  WWTP Pass/Fail Criteria for as changed as follows per
				Cake Solids	19.0% minimum
				Filtrate Solids	0.05% maximum
				Polymer Dosage	100 135 lb./dry ton solids maximum

In order to constitute a complete Bid response, you must acknowledge receipt of this addendum with the Addenda Receipt Confirmation Form in Section 4 of the ITB in your Bid. *Any Bidder not acknowledging receipt of an issued addendum may not be considered.* 

In the event additional changes or clarifications to this ITB are warranted, all Bidders are responsible for monitoring the City's Contract Opportunities site for additional addenda.

We appreciate your interest in doing business with the City of Charlotte and look forward to receiving a Bid from your company.

Sincerely,

Ryan Lingholm, CLGPO, CPPB Procurement Officer

cc: ITB Team ITB File