


EITHER OF THESE PAVEMENT SECTIONS MAY BE USED:



TYPICAL FULL-DEPTH ASPHALT PAVEMENT SECTION

- KEY**
- (R) 2'-6" STANDARD CURB AND GUTTER
  - (S) 4" CONCRETE SIDEWALK

**NOTES:**

1. USE OF VALLEY GUTTER IS PROHIBITED.
2. DEVELOPER MAY SUBMIT AN ALTERNATIVE PAVEMENT DESIGN TO CITY.
3. AN ALTERNATIVE PAVEMENT DESIGN MAY BE REQUIRED BY CDOT/NCDOT BASED ON SPECIFIC TRAFFIC PARAMETERS.
4. IF AMENITY ZONE IS AUTHORIZED IN PLACE OF PLANTING STRIP, CONCRETE SHALL BE 4" THICK AND CROSS SLOPE SHALL BE 1.5% (2% MAX).
5. PLANTING STRIP ADJACENT TO SIDEWALK SHALL BE GRADED TO 1/4" PER FOOT (MIN.) UP TO 1 1/4" PER FOOT (MAX.), EXCEPT WHERE EXCESSIVE NATURAL GRADES MAKE THIS REQUIREMENT IMPRACTICAL. IN SUCH CASES, CDOT MAY AUTHORIZE A SUITABLE GRADE.
6. 2' BUFFER CAN BE SUE OR ADDITIONAL R/W
7. IF USED IN ETJ, FULL-DEPTH ASPHALT PAVEMENT SECTION REQUIRED.

NOT TO SCALE



**CITY OF CHARLOTTE**  
**LAND DEVELOPMENT STANDARDS**  
 INCLUDES CHARLOTTE ETJ

LOCAL INDUSTRIAL STREET  
 TYPICAL SECTION

STD. NO.	REV.
U-06	23