


NOTES:

- 1. ELEVATION CONTROL POINTS SHALL BE DESIGNATED AT THE UPSTREAM INVERT (CENTER) OF THE CROSS VANE TO ESTABLISH PART OF THE PROFILE. POOL ELEVATION CONTROL POINTS OR EXCAVATION TO A SPECIFIED MAXIMUM POOL DEPTH SHALL BE DESIGNATED TO ESTABLISH THE REMAINING PROFILE. SURVEY OF CONTROL POINTS SHALL BE REQUIRED TO ESTABLISH ACCURATE CROSS VANE INSTALLATION WITHIN THE TOLERANCE SPECIFIED BY THE
- A FOOTER BOULDER IS REQUIRED IF BOULDER DEPTH IS LESS THAN DESIGN POOL DEPTH.
- BOULDERS SHOULD HAVE 2' MIN. DEPTH.
 DEEPEST PART OF POOL TO BE IN LINE WITH WHERE VANE ARM TIES INTO THE
- POOL DEPTH SHOULD BE ACCORDING TO PROFILE.



DESIGN VARIABLES			
	EXAMPLE	REACH _	REACH _
BOULDER DIMENSIONS	1'X2'X2'		
BACKFILL AND SCOUR PROTECTION MATERIAL ¹	B, 57, E		
BOULDER AND BACKFILL DEPTH	2'		
SCOUR PROTECTION DEPTH	12"		
BOULDER OFFSET	12"		
EMBEDDED LENGTH INTO BANK	3'		
VANE SLOPE 2	3%		
VANE LENGTH OUTER BEND	6'		
VANE ANGLE OUTER BEND	20°		
VANE LENGTH INNER BEND	3'		
VANE ANGLE INNER BEND	30°		
HEIGHT ABOVE HEADER	0.18'		
MAX. DROP OVER HEADER 3	0.1'		

- 1 WELL MIXED GRADATION (APPROXIMATELY 70% STONE, 20% EARTH AND 10% WOOD/MULCH) STONE MIX TO BE COMPRISED OF THE SPECIFIED MATERIALS: A = CLASS A RIP-RAP, B = CLASS B RIP-RAP, 57 = #57 STONE E = EARTH, M = MULCH, W = WOODY DEBRIS, #57 STONE NOT TO EXCEED 10% OF THE STONE MIX. THE REMAINDER OF THE MIX SHALL BE EQUAL PARTS CLASS A AND CLASS B RIP-RAP IF BOTH ARE SPECIFIED OR AS DIRECTED BY THE ENGINEER.
- 2 slope measure from header elevation over vane length where it intersects the bank. Not to exceed 5%.
- ³ TYPICAL 0.1' 0.2', NOT TO EXCEED 0.5' BASED ON HEAD OF DOWNSTREAM GRADE CONTROL.

*ENGINEER TO ADJUST AS NECESSARY, MINIMUMS CANNOT BE ADJUSTED WITHOUT CITY APPROVAL

TO SCALE NOT



CHARLOTTE-MECKLENBURG STORM WATER SERVICES GENERIC DETAIL REQUIREMENTS

ROCK J-HOOK VANE

DRAFT - NOT TO BE USED FOR CONSTRUCTION

SHEET NUMBER 1 OF 1