

# Rezoning Transportation Analysis

Petition Number: #2022-084

General Location Identifier: 02961112, 02961104, 02961111

**From:** Jake Carpenter, PE

Jacob.Carpenter@charlottenc.gov

980-221-5675

**Reviewer:**

**Travis Miller**

Travis.Miller@charlottenc.gov

980-221-5778

## Revision Log:

Date	Description
11-28-22	First Review (TM)
12-15-22	Second Review (DR)
02-22-23	Third Review (TM)
03-28-23	Fourth Review (TM)

## General Review Information

The petition is located on the south side of Ridge Road, a State-maintained major throughfare south of Mallard Creek Road, a State-maintained major throughfare. The petition is located in a northeast corridor outside Route 4, and within the limits of the Northeast Area Plan.

Active Projects Near the Site:

- N/A

---

*CDOT's review of this rezoning petition is intended to provide consistency with council adopted policies, plans, standards and guidelines including, but not limited to, the [Transportation Action Plan \(TAP\)](#), [Vision Zero](#), [Urban Street Design Guidelines \(USDG\)](#), [Center, Corridor and Wedges](#), [Charlotte BIKES](#), [Traffic Impact Study Guidelines](#) and [Charlotte WALKS](#). With a commitment to design complete streets, this review is to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.*

*This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.*

---

Based on our review of the petition, we offer the following information for your consideration.

## Transportation Summary

The petition is located on the south side of Ridge Road, a State-maintained major throughfare south of Mallard Creek Road, a State-maintained major throughfare. A Traffic Impact Study (TIS) is not needed for this site. The proposed development commits to constructing turn lanes along the site's public street frontage and constructing a 12 foot multi-use path along the site's frontage of Ridge Road. All outstanding CDOT issues have been resolved.

# Rezoning Transportation Analysis

Petition Number: #2022-084

General Location Identifier: 02961112, 02961104, 02961111

## Trip Generation


Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Vacant	-	-	Tax Record
Entitlement with Current Zoning	Single Family (R-3, 20.85 acres)	62 Dwelling Units	650	General Guidance from Planning
Proposed Zoning	<del>Multifamily (Mid-Rise)</del> <del>Attached Single Family</del> (R-17MF, 20.85 acres)	<del>288 Dwelling Units</del> <del>66 Dwelling Units</del>	1,785	Site Plan: 5/10/2022
Proposed Zoning	<del>Multifamily (Mid-Rise)</del> <del>Attached Single Family</del> (R-17MF, 20.85 acres)	<del>264 Dwelling Units</del> <del>66 Dwelling Units</del>	1,670	Site Plan: 5/10/2022
Proposed Zoning	Attached Single Family (R-17MF, 20.85 acres)	213 Dwelling Units	1,573	Site Plan: 5/10/2022

Provide comments to the specified comments below.

## Outstanding Issues

**Strikethrough = Resolved**

- ~~**Curbline:** The proposed zoning district has a setback measured from back of the existing or proposed future curbline.~~
  - ~~**Ridge Road:** The future location of curb and gutter is measured at 30 feet from the centerline of the roadway to the BOC.~~



Label and dimension the curb and gutter from the centerline for each road on the site plan.

## 2. ~~Traffic Study:~~

~~A Traffic Impact Study (TIS) is not necessary for the complete review of this petition due to the site generating less than 2,500 daily trips. If during the permitting process the site generates more than 2,500 daily trips, then a traffic study will be required.~~

# Rezoning Transportation Analysis

Petition Number: #2022-084

General Location Identifier: 02961112, 02961104, 02961111

3. ~~Revise site plan and conditional note(s) to commit to dedicate 50 feet of right of way from the road centerline. The site plan shall label and dimension the right of way from the road centerline.~~
4. ~~Site plan and conditional note(s) revisions are needed to commit to constructing internal private roads to meet or exceed CLDSM standard 11.13. Site plan shall callout CLDSM 11.13 and add roadway cross section detail.~~
5. ~~Site plan and conditional note(s) revisions are needed to commit to constructing a full three lane section on Ridge Road along the site frontage. 3 lane section to include a two-way left turn lane along the site frontage and two through lanes. Dimension the transition length and width of the two-way left turn lane along Ridge Road per NCDOT comments.~~
6. ~~Site plan and conditional note(s) revisions are needed to commit to constructing a right turn at both driveways per NCDOT comments.~~
7. ~~Site plan and conditional note(s) revisions are needed to commit to aligning site entrances with the Kings Grant rezoning (2021-028). Site plan shall show linework from Kings Grant development along Ridge Road. **Comment Rescinded 12-22-22**~~
8. ~~A site plan note(s) specifying dedication and fee simple conveyance of all rights of way to the City before the site's first building certificate of occupancy is issued as needed. CDOT requests rights of way set at 2' behind back of sidewalk where feasible.~~
9. ~~A site plan note specifying that all transportation improvements will be approved and constructed before the site's first building certificate of occupancy is issued as needed. The petitioner may phase transportation improvements if said improvements and phasing are explicitly described in site plan notes.~~
10. ~~Add conditional note "All public roadway improvements will be subject to the standards and criteria of CDOT and NCDOT, as applicable, to the roadway improvements within their respective road system authority. It is understood that such improvements may be undertaken by the Petitioner on its own or in conjunction with other development or roadway projects taking place within the broad north eastern Mecklenburg area, by way of a private/public partnership effort or other public sector project support."~~
11. ~~Revise site plan to construct a 12 foot multi-use path on Ridge Road. The site plan shall label and dimension both items from the back of curb and gutter and road centerline. The entire facility must be outside of the right of way and within a public access easement. Add conditional note committing to construction and maintenance of the 12 foot multi-use path on Ridge Road.~~

# Rezoning Transportation Analysis

Petition Number: #2022-084

General Location Identifier: 02961112, 02961104, 02961111

## Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. These requirements shall be reflected on the rezoning plan, as appropriate.

1. The setback for this district is measured from the back of the existing or future curbline as determined by CDOT and Planning during the permitting process.
2. CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte, per the City of Charlotte's Driveway Regulations.
3. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 50' x 50' sight triangles (and two 10' x 70' sight triangles on NCDOT-maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs shall not interfere with sight distance at the entrance(s) and shall be identified on the site plan.
4. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and NCDOT on NCDOT-maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
5. All proposed commercial driveway connections to a future public street will require a driveway permit submitted to CDOT for review and approval.
6. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
7. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City-maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to construction/installation. Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.
8. The petitioner needs to complete and submit the [Right of way Abandonment Petition form](#) to CDOT for review. The decision of this rezoning petition does not correlate with the decision of the possible abandonment, as this decision is issued within the separate Right of Way Abandonment process that is controlled by North Carolina General Statutes.
9. To attain a street and pedestrian lighting recommendation, the petitioner should coordinate with Anthony Mendez, CDOT. Please visit the following link:  
<https://charlottenc.gov/Transportation/Programs/Pages/StreetLighting.aspx>