

# Rezoning Transportation Analysis

Petition Number: #2022-091

General Location Identifier: 15114288

**From:** Jake Carpenter, PE

Jacob.Carpenter@charlottenc.gov

980-221-5675

**Reviewer:**

Isaiah Washington

Isaiah.Washington@charlottenc.gov

980-275-2494

## Revision Log:

Date	Description
11-28-22	First Review (IW)
01-27-23	Second Review (IW)
02-13-23	Third Review (DR)
02-22-23	Forth Review (IW)
03-28-23	Fifth Review (IW)

## General Review Information

The petition is located on the south side of Lynwood Drive, a city-maintained local road. The petition is located in the south wedge outside Route 4.

Active Projects Near the Site:

- No active projects near the site

---

*CDOT's review of this rezoning petition is intended to provide consistency with council adopted policies, plans, standards and guidelines including, but not limited to, the [Transportation Action Plan \(TAP\)](#), [Vision Zero](#), [Urban Street Design Guidelines \(USDG\)](#), [Center, Corridor and Wedges](#), [Charlotte BIKES](#), [Traffic Impact Study Guidelines](#) and [Charlotte WALKS](#). With a commitment to design complete streets, this review is to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.*

*This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.*

---

Based on our review of the petition, we offer the following information for your consideration.

## Transportation Summary

The petition is located on the south side of Lynwood Drive, a city-maintained local road. A Traffic Impact Study (TIS) is not needed for this site. Site plan is committing to dedicating 28-feet of ROW along Lynwood Drive, committing to constructing 8-foot planting strip with an 8-foot sidewalk to end of property lines on site, calling out driveway connection to public roadways as type II modified driveways 10.25E, and installing reverse angled parking spaces. All outstanding CDOT issues have been resolved.

# Rezoning Transportation Analysis

Petition Number: #2022-091

General Location Identifier: 15114288

## Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Apartments	21 Dwelling Units	210	<i>Tax Record</i>
Existing Use	Single Family Attached	18 Dwelling Units	90	<i>Tax Record</i>
Entitlement with Current Zoning	Single Family Attached (R-17MF, 1.58 acres)	26 Dwelling Units	150	<i>General Guidance from Planning</i>
Proposed Zoning	Single Family Attached (UR-2, 1.58 acres)	22 Dwelling Units	120	<i>Site Plan: 5/13/2022</i>
Proposed Zoning	Single Family Attached (UR-2, 1.58 acres)	21 Dwelling Units	110	<i>Site Plan: 1/17/2023</i>

Provide comments to the specified comments below.

## Outstanding Issues

**Strikethrough = Resolved**

- ~~1. **Outstanding comment from 11-28-22** **Curblin**: The proposed zoning district has a setback measured from back of the existing or proposed future curblin.~~
  - ~~a. **Lynnwood Drive**: The future location of curb and gutter should follow the CLDSM Local Residential Medium Street which is measured at 13 feet from the centerline of the roadway to the BOC.~~

~~**Clarifying comment 01-26-23**: Site plan should show dimension from centerline to back of curb.~~


~~Label and dimension the curb and gutter from the centerline for each road on the site plan.~~
- ~~2. **Traffic Study**:  
A Traffic Impact Study (TIS) is not necessary for the complete review of this petition due to the site generating less than 2,500 daily trips. If during the permitting process the site generates more than 2,500 daily trips, then a traffic study will be required.~~
- ~~3. Revise conditional note(s) to commit to dedicate 28 feet of right of way from the road centerline in coordination per CLDSM Local Residential Medium Street. The site plan shall label and dimension the right of way from the road centerline.~~
- ~~4. Revise site plan and conditional note(s) to remove angled parking and install parallel parking on Lynnwood Drive.~~

~~**Comment Clarification 01-27-23**: CDOT is comfortable with the reverse angled parking given context of the existing street network and neighborhood development. Add conditional note stating that appropriate signage for reverse angle parking will be coordinated with CDOT during permitting.~~
- ~~5. Revise site plan and conditional note(s) to call out driveway connection to public roadways as type II modified driveways 10.25E~~
- ~~6. Revise site plan and conditional note(s) to show 8 foot planting strip and 8' sidewalk extended to property line.~~

# Rezoning Transportation Analysis

Petition Number: #2022-091

General Location Identifier: 15114288



7. ~~Outstanding comment from 11-28-23:~~ A site plan note(s) specifying dedication and fee simple conveyance of all rights-of-way to the City before the site's first building certificate of occupancy is issued as needed. CDOT requests rights-of-way set at 2' behind back of sidewalk where feasible.

~~Clarifying Comment 01-27-23:~~ Site plan should update conditional note 7 under Transportation to state SUE to be 2' behind sidewalk and not 1' so that CDOT can do maintenance when necessary.

8. ~~Add conditional note "All public roadway improvements will be subject to the standards and criteria of CDOT and NCDOT, as applicable, to the roadway improvements within their respective road system authority. It is understood that such improvements may be undertaken by the Petitioner on its own or in conjunction with other development or roadway projects taking place within the broad north eastern Mecklenburg area, by way of a private/public partnership effort or other public sector project support."~~

## Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. These requirements shall be reflected on the rezoning plan, as appropriate.

1. The setback for this district is measured from the back of the existing or future curbline as determined by CDOT and Planning during the permitting process.
2. CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte, per the City of Charlotte's Driveway Regulations.
3. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 50' x 50' sight triangles (and two 10' x 70' sight triangles on NCDOT-maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs shall not interfere with sight distance at the entrance(s) and shall be identified on the site plan.
4. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and NCDOT on NCDOT-maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
5. All proposed commercial driveway connections to a future public street will require a driveway permit submitted to CDOT for review and approval.
6. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
7. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City-maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to construction/installation.

## Rezoning Transportation Analysis

**Petition Number: #2022-091**

*General Location Identifier: 15114288*

Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.

8. The petitioner needs to complete and submit the [Right of way Abandonment Petition form](#) to CDOT for review. The decision of this rezoning petition does not correlate with the decision of the possible abandonment, as this decision is issued within the separate Right of Way Abandonment process that is controlled by North Carolina General Statutes.
9. To attain a street and pedestrian lighting recommendation, the petitioner should coordinate with Anthony Mendez, CDOT. Please visit the following link:  
<https://charlottenc.gov/Transportation/Programs/Pages/StreetLighting.aspx>