



**MECKLENBURG COUNTY**  
**Land Use & Environmental Services Agency**

**MEMORANDUM**

To: Charlotte-Mecklenburg Planning Commission  
From: LUESA, Mecklenburg County  
Date: 4.27.23  
Subject: Rezoning Petition Comments

Charlotte-Mecklenburg Planning Commission  
600 East Fourth Street Charlotte, North Carolina 28202

Mecklenburg County has reviewed the City of Charlotte rezoning petition below to identify regulatory requirements of the petitioner; inform the petitioner, planning staff, and other affected parties of such regulatory requirements; and identify potential effects on, and impacts from, nearby properties.

|   |   |
|---|---|
| <b><u>Petitioner Information:</u></b><br>Scott Allred<br>Precept Construction, LLC<br>118 E. Avondale Dr<br>Greensboro, NC, 27403<br>Home Phone:<br>336-286-6811<br>scott@preceptconstruction.com | <b><u>Parcel GIS ID(s):</u></b><br>10938108 |
|---|---|

**2022-219: 9600 Albemarle Road**

*Air Quality Comments:* Development of this site may require submission of an asbestos Notification of Demolition and Renovation to MCAQ due to possible demolition or relocation of an existing structure. A letter of notification and the required forms have been mailed directly to the petitioner by MCAQ.

Mecklenburg County Air Quality recommends that the proposed multifamily development be constructed with at least 10% EV-ready parking spaces. EV-ready spaces are those that have pre-installed electrical panel capacity with a dedicated circuit, raceway with conduit, and either a junction box or 240V outlet. It is typically 3-4 times less expensive to install EV charging infrastructure during initial construction versus retrofitting due to the increased costs from demolition, trenching, and redundant permitting fees. As a point of reference, the LEED (Leadership in Energy Efficiency and Design) standard for Electric Vehicles in New Construction requires developers to install electrical vehicle supply equipment in 5% of

all parking or make 10% of all parking spaces EV-ready. More information on these standards can be found in LEED v4.1: Building Design and Construction: New Construction located at: [www.usgbc.org](http://www.usgbc.org).

*Ground Water Services Comments:*

Groundwater & Wastewater Services records indicate contamination site(s) exist on or within 1,500 feet of the property included in the petition. An established Area of Regulated Groundwater Usage (ARGU) as defined by the Mecklenburg County Groundwater Well Regulations extends 1,500 feet around the contamination sites. In an ARGU where municipally supplied water is available water supply wells for potable water supply, irrigation or open loop geothermal systems may not be permitted or constructed on or within 1,000 feet of contamination sites. Wells may be permitted with special construction and sampling requirements between 1,000 and 1,500 feet of contamination sites.

Groundwater & Wastewater Services records indicate a temporarily abandoned water supply well is registered at this location. Please note that any wells on this parcel need to be located, flagged and protected prior to development or be permanently abandoned in accordance with the Mecklenburg County Groundwater Well Regulations. A permit from GWS is required for permanent well abandonments. The abandonments must be completed by a North Carolina Certified Well Contractor.

Review of NCDEQ records indicates this property is part of Inactive Hazardous Sites Branch (IHSB) listing for Palomino Club, NONCD0002256, based on chlorinated solvents detected in the onsite water supply well. Any development on this parcel should comply with applicable NCDEQ requirements for management of this contamination site. Pls contact Collin Day with NCDEQ IHSB for more info.

Collin Day  
Environmental Supervisor  
NC Department of Environmental Quality, Winston-Salem Regional Office  
Division of Waste Management, Superfund Section-IHSB Western Region

Voice: (336) 776-9675  
Mobile: (919) 614-5702  
Fax: (336) 776-9797  
Email: [collin.day@ncdenr.gov](mailto:collin.day@ncdenr.gov)

Information from property records indicates the use of oil, wood, or coal as a heating fuel and records also indicated the year built as 1954, so the property may contain an underground or above ground fuel oil storage tank. Any existing tank and its contents should be removed, following applicable NCDEQ guidance, prior to any demolition or grading activity.

*Storm Water Services Comments:* No Comments

*Solid Waste Comments:* No Comments

**Department Contacts:**

**PEOPLE ● PRIDE ● PROGRESS ● PARTNERSHIP**  
**2145 Suttle Avenue ● Charlotte, North Carolina 28208 ● Fax 980.335.2253**  
**[www.mecknc.gov](http://www.mecknc.gov)**

Petitioners seeking to address individual comments and issues may follow up with the following Mecklenburg County staff:

*Air Quality Comments:* PJ McKenzie - (paul.mckenzie@mecklenburgcountync.gov)

*Ground Water Services:* Shawna Caldwell - (shawna.caldwell@mecklenburgcountync.gov)

*Storm Water Services:* Myrette Stephen - (myrette.stephen@mecklenburgcountync.gov)

*Solid Waste Comments:* Joe Hack - (joe.hack@mecklenburgcountync.gov)

Additionally, please CC Erin Stanforth, (erin.stanforth@mecklenburgcountync.gov) on all communications to individual departments.

**MCAQ Scope of Review:**

Mecklenburg County Air Quality (MCAQ) has reviewed the petitions with regard to air quality regulations for stationary sources and demolition and/or renovation of structures (e.g. National Emission Standards for Hazardous Air Pollutants for asbestos). Comments may also be made regarding incompatible land uses, sources of Toxic Air Pollutants, proximity to Risk Management Plan facilities, and proximity to known nuisance conditions or sensitive populations. MCAQ has conducted the review based on information submitted by the petitioner, review of aerial photographs (as available through the Mecklenburg County Polaris system), review of the “Air Pollution Facility Information Online” database available from the MCAQ website, and review of Mecklenburg County Health Department records. The review is cursory based on limited information provided within petition applications and site plans.