

PLAN REVIEW SHEET

Date: 3/26/2024

Petition #: 2023-156

Staff Contact: Evan Punch

The Site is located at 2501 W.T. Harris and is served by CATS bus route #29. CATS requests the

construction of an ADA-compliant bus standard detail 60.01A along the W.T. Harris. The final location

will be coordinated with the developer during the Land Development plan review process.

LEGEND BOARDING AND ALIGHTING AREA BUS SIGN SIDEWALK MUST MATCH SLOPE OF BOARDING AND ALIGHTING AREA CONCRETE 4" THICK TRASH RECEPTACLE RIGHT OF WAY NOTES STANDARDS, VARIATIONS MUST BE APPROVED THROUGH CATS AND CDOT PROJECT MANAGER. PLANTING STRIP 2' MIN. WIDTH, VARIES -CURB 2. WIDTH OF EXISTING SIDEWALK PLUS PLANTING STRIP WIDTH MUST EQUAL 8' WIDE. IF WIDTH IS LESS THAN 8', EXISTING SIDEWALK MUST BE REPLACED WITH WIDER SIDEWALK TO OBTAIN 8' WIDTH. 4 GUTTER STREET PLAN VIEW SEE SHEET NO. 60.07A, 60.07B, AND 60.07C FOR ADDITIONAL DETAILS AND NOTES. REVISIONS NO. DATE DESCRIPTION APPROVED DATE BUS STOP WITH PLANTING VI S STRIP, MINIMUM WIDTH STD. NO. REV. 60.01A