

Rezoning Transportation Analysis

Petition Number: 2023-014

General Location Identifier: 04506107

From: Jake Carpenter, PE
Jacob.carpenter@charlottenc.gov
980-221-5675

Reviewer: Travis Miller
Travis.Miller@charlottenc.gov
980-221-5778

Revision Log:

Date	Description
6-28-23	First Review (ME)
7-28-23	Second Review (ME)
8-28-23	Third Review (ME)

General Review Information

The petition is located adjacent to Cannon Avenue, a City-maintained minor collector, east of Wild Rose Lane, a City-maintained local street. The petition is located in a north corridor outside of Route 4.

Active Projects Near the Site:

- N/A

CDOT's review of this rezoning petition is intended to provide consistency with council adopted policies, plans, standards and guidelines including, but not limited to, the [Transportation Action Plan \(TAP\)](#), [Vision Zero](#), [Urban Street Design Guidelines \(USDG\)](#), [Center, Corridor and Wedges](#), [Charlotte BIKES](#), [Traffic Impact Study Guidelines](#) and [Charlotte WALKS](#). With a commitment to design complete streets, this review is to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.

This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.

Based on our review of the petition, we offer the following information for your consideration.

Transportation Summary

The site is located adjacent to Cannon Avenue, a City-maintained minor collector, east of Wild Rose Lane, a City-maintained local street. A Traffic Impact Study (TIS) is not required for this site due to the site generating less than 2500 daily trips. The proposed site plan will generate less vehicular trips than what is currently entitled under the existing zoning. CDOT has coordinated with the petitioner on construction of an 8 ft planting strip and 6 ft sidewalk along Cannon Ave. All outstanding CDOT issues have been addressed.

Rezoning Transportation Analysis

Petition Number: 2023-014

General Location Identifier: 04506107

Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Single Family Detached	1 Dwelling Unit	10	Tax Record
Entitled Use	Single Family (R-4, 1.29 acres)	5 Dwelling Units	50	General Guidance from Planning
Proposed Use	Off-street Parking* (B-2, 1.29 acres)	-	-	Site Plan: 08-05-22

*To accommodate accessory off-street parking on the site that will serve the adjacent use on Tax Parcel No. 04506107. Will not generate any trips.

Petitioner to provide responses to the staff comments below as well as specify other changes to the site plan.

Outstanding Issues

Strikethrough = Resolved

1. ~~Traffic Study:~~

~~A Traffic Impact Study (TIS) is not required for the complete review of this petition due to the site generating less than 2,500 daily trips and/or not triggering any other City TIS requirements.~~

2. ~~Curblines:~~

~~a. **Cannon Avenue:** Location of curb and gutter to be installed to 17.5 feet from roadway centerline to accommodate the Charlotte Streets Map with a roadway typical section of a collector road.~~

~~NOTE: Additional distance from center line to back of curb may be required in locations where a median is present or around intersections and interchanges.~~

~~Label and dimension the curb and gutter from the centerline for each road on the site plan.~~

Clarifying comment 7.28.2023: Correct label to state that back of curb will be located 17.5 ft from the roadway centerline of Cannon Avenue.

~~Reference (CLDSM standard detail U-07A) for street typical.~~

~~3. Revise site plan and conditional note(s) to commit to dedicate 33.5 ft right-of-way from the road centerline. The site plan shall label and dimension the right-of-way from the road centerline.~~

~~4. Revise site plan and conditional note(s) to commit to construct an 8-foot planting strip, and 6-foot sidewalk on Cannon Ave per Chapter 19 / Chapter 20. The site plan shall label and dimension both items from the back of curb and gutter or edge of pavement.~~

~~5. Add a conditional note specifying "A Right of Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City-maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to construction/installation. Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements."~~

Rezoning Transportation Analysis

Petition Number: 2023-014

General Location Identifier: 04506107

- ~~6. Revise site plan and conditional note(s) to commit to meet site frontage requirements per what is outlined by CDOT Land Development and the City of Charlotte Land Development Standards Manual.~~
7. **CDOT REQUEST:** Revise site plan and conditional note(s) to commit to installing 2' 6" curb and gutter from site frontage to existing curb and gutter east of site.
- ~~8. Add a conditional note specifying "the Petitioner shall dedicate and convey in fee simple all rights-of-way to the City before the site's first building certificate of occupancy is issued. CDOT requests rights-of-way set at 2' behind back of sidewalk where feasible."~~
- ~~9. Add a conditional note specifying "All transportation improvements will be approved and constructed before the site's first building certificate of occupancy is issued. The petitioner may phase transportation improvements if said improvements and phasing are explicitly described in site plan notes."~~

Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. These requirements shall be reflected on the rezoning plan, as appropriate.

1. CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte, per the City of Charlotte's Driveway Regulations.
2. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' sight triangles (and two 10' x 70' sight triangles on NCDOT-maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs shall not interfere with sight distance at the entrance(s) and shall be identified on the site plan.
3. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and NCDOT on NCDOT-maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
4. All proposed commercial driveway connections to a future public street will require a driveway permit submitted to CDOT for review and approval.
5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
6. To obtain a street and pedestrian lighting recommendation, the petitioner should visit the following link: <https://charlottenc.gov/Transportation/Programs/Pages/StreetLighting.aspx>