

# Rezoning Transportation Analysis

Petition Number: 2023-092

General Location Identifier: 19959104, 19959103

**From:** Jake Carpenter, PE

Jacob.Carpenter@charlottenc.gov

980-221-5675

**Reviewer:**

**Natalie King**

Natalie.King@charlottenc.gov

980-417-0206

## Revision Log:

Date	Description
9-28-23	First Review (NK)
11-27-23	Second Review (JP)
1-24-24	Third Review (JP)

## General Review Information

The petition is adjacent to Steele Creek Road, a State-maintained major arterial, south of Entrance Drive, a privately-maintained local street. The petition is located in the Shopton Road activity center outside Route 4, within the I-485 Interchange Analysis Study.

## Active Projects Near the Site:

- CIP: Steele Creek Road (NC-160) Widening
  - Project ID: SP\_4
  - Location: Steele Creek Road between Shopton Road and South Carolina State Line
  - Project Type: Pedestrian and Bike
  - Project Phase: Planning
  - Anticipated Start Date: Late 2024
  - Controlling entity: NCDOT Division 10
  - Project Manager Phone: 704-982-0101
  - Project Impact: Creates Complete Street

---

*CDOT's review of this rezoning petition is intended to provide consistency with council adopted policies, plans, standards and guidelines including, but not limited to, the [Transportation Action Plan \(TAP\)](#), [Vision Zero](#), [Urban Street Design Guidelines \(USDG\)](#), [Center, Corridor and Wedges](#), [Charlotte BIKES](#), [Traffic Impact Study Guidelines](#) and [Charlotte WALKS](#). With a commitment to design complete streets, this review is to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.*

*This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.*

---

Based on our review of the petition, we offer the following information for your consideration.

## Transportation Summary

The petition is adjacent to Steele Creek Road, a State-maintained major arterial, south of Entrance Drive, a privately-maintained local street. A Traffic Impact Study (TIS) is not required for the site due to the development generating site trips under ordinance thresholds and not meeting additional TIS triggers. Site plan revisions needed to align the sidewalk across the driveway. Further details are listed below.

# Rezoning Transportation Analysis

Petition Number: 2023-092

General Location Identifier: 19959104, 19959103

## Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Vacant	-	0	Tax Record
Entitlement with Current Zoning	Single Family (N1-A 4.85 acres)	14 Dwelling Units	170	General Guidance from Planning
Proposed Zoning	Self-Storage (ML-1, 4.85 acres)	122,500	178	Site Plan: 06-02-23

Petitioner to provide responses to the staff comments below as well as specify other changes to the site plan.

## Outstanding Issues

**Strikethrough = Resolved**

### 1. ~~Curbline:~~

- a. ~~Steele Creek Road:~~ Location of back of curb and gutter to be moved to 41 feet from roadway centerline to accommodate the Charlotte Streets Map.

~~The required cross section is 4+ Boulevard, Buffered/Separated Bike Lanes~~

~~Label and dimension the curb and gutter from the centerline for each road on the site plan.~~

### 2. ~~Comprehensive Transportation Review (CTR):~~

~~A Traffic Impact Study (TIS) is not required for the complete review of this petition due to the site generating site trips under ordinance thresholds found in the Charlotte Streets manual Table 3.1 and/or not triggering any other City TIS requirements.~~

3. ~~Revise site plan and conditional note(s) to commit to dedicate 50' right-of-way from the road centerline. The site plan shall label and dimension the right-of-way from the road centerline.~~

4. ~~Revise site plan and conditional note(s) to commit to construct bicycle facilities by locating the curb and gutter 41' from the center line.~~

5. ~~Add a conditional note specifying "A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City-maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to construction/installation. Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements."~~


6. ~~Revise site plan to commit to extending the existing median to the intersection of the I-485 ramp and Steele Creek Road in coordination with NCDOT.~~

# Rezoning Transportation Analysis

Petition Number: 2023-092

General Location Identifier: 19959104, 19959103

7. Revise site plan to align the sidewalk across the driveway.



8. ~~Add a conditional note stating that any security gates must be installed 40' from the edge of pavement /beginning of the driveway in coordination with NCDOT.~~

9. ~~Add a conditional note specifying "the Petitioner shall dedicate and convey in fee simple all rights-of-way to the City before the site's first building certificate of occupancy is issued. CDOT requests rights-of-way set at 2' behind back of sidewalk where feasible."~~

10. ~~Add a conditional note specifying "All transportation improvements will be approved and constructed before the site's first building certificate of occupancy is issued."~~

~~The petitioner may phase transportation improvements if said improvements and phasing are approved by CDOT and explicitly described in site plan notes.~~

11. ~~Add conditional note specifying "All public roadway improvements will be subject to the standards and criteria of CDOT and NCDOT, as applicable, to the roadway improvements within their respective road system authority. It is understood that such improvements may be undertaken by the Petitioner on its own or in conjunction with other development or roadway projects taking place within the broad southern Mecklenburg area, by way of a private/public partnership effort or other public sector project support."~~

# Rezoning Transportation Analysis

Petition Number: 2023-092

General Location Identifier: 19959104, 19959103

## Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. These requirements shall be reflected on the rezoning plan, as appropriate.

1. CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte, per the City of Charlotte Unified Development Ordinance.
2. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 50' x 50' sight triangles (and two 10' x 70' sight triangles on NCDOT-maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs shall not interfere with sight distance at the entrance(s) and shall be identified on the site plan.
3. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and NCDOT on NCDOT-maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and to comply with City of Charlotte Unified Development Ordinance regulations.
4. All proposed commercial driveway connections to a future public street will require a driveway permit submitted to CDOT for review and approval.
5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
6. To obtain a street and pedestrian lighting recommendation, the petitioner should visit the following link: <https://charlottenc.gov/Transportation/Programs/Pages/StreetLighting.aspx>