

# Rezoning Transportation Analysis

Petition Number: 2023-176

General Location Identifier: 05921226

**From: Jake Carpenter, PE**

Jacob.Carpenter@charlottenc.gov

980-221-5675

**Reviewer:**

**Isaiah Washington**

Isaiah.Washington@charlottenc.gov

980-275-2494

## Revision Log:

Date	Description
01-23-24	First Review (IW)
02-21-24	Second Review (IW)

## General Review Information

The petition is located at the intersection of Little Rock Road, a State-maintained major arterial, and Paw Creek Road, a City-maintained minor arterial. The petition is located in a northwest wedge outside of Route 4, within the Westside Strategy Plan Study.

### Active Projects Near the Site:

- There are no known active projects in the vicinity.

---

*CDOT's review of this rezoning petition is intended to provide consistency with council adopted policies, plans, standards and guidelines including, but not limited to, the [Transportation Action Plan \(TAP\)](#), [Vision Zero](#), [Urban Street Design Guidelines \(USDG\)](#), [Center, Corridor and Wedges](#), [Charlotte BIKES](#), [Traffic Impact Study Guidelines](#) and [Charlotte WALKS](#). With a commitment to design complete streets, this review is to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.*

*This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.*

---

Based on our review of the petition, we offer the following information for your consideration.

## Transportation Summary

The site is located at the intersection of Little Rock Road, a State-maintained major arterial, and Paw Creek Road, a City-maintained minor arterial. Based on the 917 daily trips, the petitioner will be required to satisfy Tier 1 Multimodal assessment (3 points). Site plan and/or conditional note revisions are needed including completion of the CTR and addition of those commitments to the conditional notes. Further details are listed below.

# Rezoning Transportation Analysis

Petition Number: 2023-176

General Location Identifier: 05921226

## Trip Generation

Scenario	Land Use	Intensity	Trip Generation			Source
			Daily Trips	AM Peak Hour Trips	PM Peak Hour Trips	
Existing Use	Single Family	1 Dwelling Unit	15	1	1	<i>Tax Record</i>
Entitlement with Current Zoning	Single Family (N1-A, 14.85 acres)	44 Dwelling Units	475	35	46	<i>General Guidance from Planning</i>
Proposed Zoning	Single Family Attached (N2-A, 14.85 acres)	127 Dwelling Units	917	60	72	<i>Site Plan: 12-22-23</i>

**Petitioner to provide responses to the staff comments below as well as specify other changes to the site plan.**

### Outstanding Issues

**Strikethrough = Resolved**

**1. Curblines:**

~~a. **Paw Creek Road:** Location of future back of curb and gutter to be moved 24' from Centerline.~~

~~2+ Avenue, Bike Lanes per the Charlotte Streets Map~~

~~Label and dimension the curb and gutter from the centerline for each road on the site plan.~~

**2. Comprehensive Transportation Review (CTR):**

A Traffic Impact Study (TIS) is not required for the complete review of this petition due to the site generating site trips under ordinance thresholds found in the Charlotte Streets manual Table 3.1 and/or not triggering any other City TIS requirements.

The petition's zoning falls within the low intensity development which based on the 917 daily trips will trigger Tier 1 (3 mitigation points) for multimodal assessment. The petitioner shall review and assess the publicly accessible pedestrian network within ¼ mile walking distance of the site to identify multimodal infrastructure to meet the Tier 1 (3 mitigation points) for multimodal assessment.

**Clarifying comment 02.21.24:** See Table 3.3 Multimodal Assessment Mitigation Options in the Charlotte Streets Manual for guidance. Complete CTR summary table and include on the revised plan. CTR table link (use Site Data Table – CTR Summary tab): <https://www.charlottenc.gov/files/sharedassets/city/v/2/growth-and-development/documents/dev-center-fees/resources/udo-site-data-tables-curb-ramps-and-ctr.xlsx>

~~3. Revise site plan and conditional note(s) to commit to dedicate 38' of right of way from the road centerline. The site plan shall label and dimension the right of way from the road centerline.~~

~~4. Add a conditional note specifying "A Right of Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right of way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be~~

# Rezoning Transportation Analysis

Petition Number: 2023-176

General Location Identifier: 05921226

~~approved by CDOT prior to construction/installation. Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements."~~

- ~~5. Add a conditional note specifying "the Petitioner shall dedicate and convey in fee simple all rights-of-way to the City before the site's first building certificate of occupancy is issued. CDOT requests rights-of-way set at 2' behind back of sidewalk where feasible."~~
- ~~6. Add a conditional note specifying "All transportation improvements will be approved and constructed before the site's first building certificate of occupancy is issued."~~

~~The petitioner may phase transportation improvements if said improvements and phasing are approved by CDOT and explicitly described in site plan notes.~~

~~Update conditional note III.5. to remove the word "offsite" as all public transportation infrastructure will need to be completed prior to first CO which includes sidewalk along Paw Creek.~~

## Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. These requirements shall be reflected on the rezoning plan, as appropriate.

1. CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte, per the City of Charlotte Unified Development Ordinance.
2. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 50' x 50' sight triangles (and two 10' x 70' sight triangles on NCDOT-maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs shall not interfere with sight distance at the entrance(s) and shall be identified on the site plan.
3. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and NCDOT on NCDOT-maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and to comply with City of Charlotte Unified Development Ordinance regulations.
4. All proposed commercial driveway connections to a future public street will require a driveway permit submitted to CDOT for review and approval.
5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
6. To obtain a street and pedestrian lighting recommendation, the petitioner should visit the following link: <https://charlottenc.gov/Transportation/Programs/Pages/StreetLighting.aspx>