

REZONING PLAN NOTES

- FIRE DEPARTMENT ACCESS ROAD SHALL HAVE A MIN. 20' UNOBSTRUCTED CLEAR WIDTH AND SHALL BE CAPABLE OF SUPPORTING 85,000 POUNDS.
- 2. TURN RADIUS 30' INSIDE AND 42'-3 ½" OUTSIDE.
- 3. FOR BUILDINGS THAT ARE EQUIPPED WITH A SPRINKLER SYSTEM, A FIRE DEPARTMENT CONNECTION SHALL BE LOCATED WITHIN 200' OF A FIRE HYDRANT FOR A NFPA 13 SPRINKLER SYSTEM.
- 4. FIRE HYDRANT SHALL BE LOCATED WITHIN 400' TO THE MOST REMOTE POINT OF BUILDING AS TRUCK TRAVEL FOR AL BUILDINGS.

PERMITTED USES


- OFFICE
- 2. RESEARCH AND DEVELOPMENT
- 3. RECEPTION FACILITY (UNDER PRESCRIBED CONDITIONS
- 4. MEDICAL / DENTAL OFFICE

SITE DEVELOPMENT DATA

- SITE ADDRESS: 6425 AND 6409 BROOKSHIRE BOULEVARD
- 2. PARCEL ID: 03505512, 03505513

CHARLOTTE, NC 28216

- 3. CURRENT ZONING: ML-2
- 4. PROPOSED ZONING: IMU
- 5. SETBACKS: 20 FT FRONT SETBACK 20 FT SIDE SETBACK 20 FT REAR SETBACK
- 6. REQUIRED BUFFER: CLASS B LANDSCAPE YARD WITH 25' MINIMUM WIDTH
- 7. TOTAL SITE ACREAGE: 7.4 ACRES
- 8. EXISTING USES: OFFICE
- 9. PROPOSED USES: OFFICE
- 10. PARKING: PARKING WILL BE PROVIDED AS REQUIRED BY THE UDO.



5/15/2024 DESIGNED BY 1" = 100'

SHEET NO.
RZ-100

