



MECKLENBURG COUNTY
Land Use & Environmental Services Agency

MEMORANDUM

To: Charlotte-Mecklenburg Planning Commission

From: LUESA, Mecklenburg County

Date: 10.23.25

Subject: Rezoning Petition Comments

Charlotte-Mecklenburg Planning Commission
600 East Fourth Street Charlotte, North Carolina 28202

Mecklenburg County has reviewed the City of Charlotte rezoning petition below to identify regulatory requirements of the petitioner; inform the petitioner, planning staff, and other affected parties of such regulatory requirements; and identify potential effects on, and impacts from, nearby properties.

<u>Petitioner Information:</u> Ravin Partners 558 E Brooklyn Vlg Ave Suite 120 Charlotte, NC, 28202 Home Phone: 704-714-9640 Work Phone: 980-334-2003 lisa.arnold@alexanderricks.com	<u>Parcel GIS ID(s):</u> 19312102
<u>Existing Zoning:</u> CG(CD), N2-B(CD)	<u>Proposed Zoning:</u> CG(CD), N2-A (CD) SPA <u>Primary Proposed Zoning:</u> CG-CD General Commercial Zoning District Conditional <u>Request Type:</u> Conditional (Tier 2)
<u>Current Use:</u> Vacant	<u>Proposed Use:</u>

2025-109: NWR- Sardis SPA

Air Quality Comments: The petitioner will be notified of the local dust ordinance requiring property owners, and their contractors, to minimize dust leaving their property.

MCAQ recommends that the parking area for each dwelling be pre-wired for an EV charging station (i.e. EV-ready).

Ground Water Services Comments: Executive Summary: Contamination incidents exist in the vicinity, so there may be restrictions for water supply wells. Additionally, parcel 193-121-02 may contain an underground or above ground storage tank.

Groundwater & Wastewater Services records indicate contamination site(s) exist on or within 1,500 feet of the property included in the petition. An established Area of Regulated Groundwater Usage (ARGU) as defined by the Mecklenburg County Groundwater Well Regulations extends 1,500 feet around the contamination sites. In an ARGU where municipally supplied water is available water supply wells for potable water supply, irrigation or open loop geothermal systems may not be permitted or constructed on or within 1,000 feet of contamination sites. Wells may be permitted with special construction and sampling requirements between 1,000 and 1,500 feet of contamination sites.

Information from property records indicate that the building(s) on parcel 193-121-02 uses or previously utilized oil, wood or coal heat. Based on this the property may contain an underground or above ground fuel oil storage tank. The tank and its contents should be removed, following applicable NCDEQ guidance, prior to any demolition or grading activity.

Storm Water Services Comments: A Floodplain Development Permit from the City of Charlotte is required for all proposed construction within the regulated floodplain. There are specific building requirements for any proposed structure located within the regulated floodplain. See City of Charlotte Unified Development Ordinance Article 27 for details.

Solid Waste Comments: No comments

Department Contacts:

Petitioners seeking to address individual comments and issues may follow up with the following Mecklenburg County staff:

Air Quality Comments: Megan Green - (megan.green@mecklenburgcountync.gov)

Ground Water Services: Shawna Caldwell - (shawna.caldwell@mecklenburgcountync.gov)

Storm Water Services: Myrette Stephen - (myrette.stephen@mecklenburgcountync.gov)

Solid Waste Comments: Joe Hack - (joe.hack@mecklenburgcountync.gov)

Additionally, please CC Erin Stanforth, (erin.stanforth@mecklenburgcountync.gov) on all communications to individual departments.

MCAQ Scope of Review:

Mecklenburg County Air Quality (MCAQ) has reviewed the petitions with regard to air quality regulations for stationary sources and demolition and/or renovation of structures (e.g. National Emission Standards for Hazardous Air Pollutants for asbestos). Comments may also be made regarding incompatible land uses, sources of Toxic Air Pollutants, proximity to Risk Management Plan facilities, and proximity to known nuisance conditions or sensitive populations. MCAQ has conducted the review based on information submitted by the petitioner, review of aerial photographs (as available through the Mecklenburg County Polaris system), review of the "Air Pollution Facility Information Online" database available from the MCAQ website, and review of Mecklenburg County Health Department

records. The review is cursory based on limited information provided within petition applications and site plans.