NOTE:


- 1. 1/2" EXPANSION JOINTS REQUIRE INSTALLATION OF ONE 1/2" THICK PIECE OF BITUMINOUS FIBER THROUGH THE ENTIRE SLAB. JOINT MATERIAL SHOULD BE PLACED FLUSH WITH CONCRETE.
- TO LIMIT STORM WATER FLOW DOWN DRIVEWAYS. USE STANDARD 10.24C FOR DRIVEWAYS NEAR LOW POINTS.
- 3. ALL DRIVEWAYS MUST MEET THE CURRENT CITY DRIVEWAY REGULATIONS AND NCDOT REQUIREMENTS FOR SPACING, SIGHT DISTANCE AND OFFSETS FROM PROPERTY LINES AND INTERSECTIONS.
- 4. "A" BREAKOVER SHALL BE 8% OR LESS (A = ALGEBRAIC DIFFERENCE).
- PRIOR APPROVAL IS REQUIRED BY CDOT ON GRADES EXCEEDING WHAT ARE SHOWN.
- 6. ** PER NC IFC SECTION D103.2, FIRE APPARATUS ACCESS ROADS SHALL NOT EXCEED 10 PERCENT IN GRADE.
- 7. REFER TO CHAPTER 32 OF THE UDO FOR MODIFICATIONS RELATED TO TREE PRESERVATION OR CONSTRAINED SPACES.

GENERAL NOTES:


- ALL CONCRETE TO BE 3600 P.S.I. COMPRESSIVE STRENGTH.
- ALL CURB, CURB AND GUTTER AND SIDEWALKS ARE TO BE REMOVED TO THE NEAREST JOINT BEYOND NEW CONSTRUCTION OR CUT WITH A SAW AND REMOVED.
- SAW CUT OR JOINT TO BE PERPENDICULAR TO EDGE OF EXISTING PAVEMENT.
- SEE STD. NO 10.17B FOR DETAIL OF EXPANSION JOINT AND GROOVE JOINT.


DRIVEWAY APRON WIDTH		
TYPE DRIVEWAY	MINIMUM	MAXIMUM
TYPE I-RESIDENTIAL LOCAL/COLLECTOR ARTERIAL *	10' 15'	24' 24'
ONE-WAY TYPE II COMMERCIAL	20'	30'
TWO-WAY TYPE II COMMERCIAL	26'	50'

MUST PROVIDE ON-SITE TURNAROUND



SECTION A - A





(2.00% MAX.)



CITY OF CHARLOTTE LAND DEVELOPMENT STANDARDS

INCLUDES CHARLOTTE ETJ

COMMERCIAL TYPE II AND RESIDENTIAL TYPE I DROP CURB DRIVEWAY WITH SIDEWALK ABUTTING CURB STD. NO. REV. (6" X 18" VERTICAL CURB)

10.24B