



- | NO. | DESCRIPTION: |
|-----|---|
| 1. | RUN X 12" RMJ TEE. |
| 2. | 12" 45° BEND MJ-MJ FITTINGS WITH FOSTER ADAPTORS (ROTATE AS REQ'D). |
| 3. | 12" 11¼° BEND MJ-MJ FITTINGS WITH FOSTER ADAPTORS. |
| 4. | 12" X 8" REDUCER MJ-MJ FITTINGS WITH FOSTER ADAPTORS (OR) 8" X 18" DIP SHORT (OR) 8" X 13" SWIVEL ADAPTER. |
| 5. | 8" GATE VALVE (RMJ-RMJ). |
| 6. | 8" 45° BEND MJ-MJ FITTINGS WITH FOSTER ADAPTOR. |
| 7. | 8" RJ DIP (PE-PE) LENGTH AS REQ'D. |
| 8. | 8" GATE VALVE (RMJ-RMJ). |
| 9. | HIGH VELOCITY FIRE HYDRANT PAINTED OSHA SAFETY BLUE - W/TWO HOSE & TWO STORZ PUMPER NOZZLES AND 8" SHOE CONNECTION (INSTALLATION PER THE FH STANDARD DETAIL). |
| 10. | VALVE BOX ASSEMBLY W/ VALVE EXTENSION ASSEMBLY (AS REQ'D) PER CLTW STD. DETAILS. |
| 11. | MINIMUM 9 CUBIC FEET OF #57 WASHED STONE PROPORTIONALLY AROUND BASE. DO NOT COVER WEEP HOLE. ENCAPSULATE FILTER FABRIC AROUND WASHED STONE. |
| 12. | COMPACTED BEDDING STONE - #57 WASHED STONE TO MIDPOINT OF MAIN & 6" ABOVE B.O. PIPING. |
| 13. | ALL PIPE & FITTINGS SHALL BE RESTRAINED. FITTINGS 12" & SMALLER SHALL CONFORM TO AWWA C-153 FOR COMPACT FITTINGS. |
| 14. | FOSTER ADAPTOR. |

NOTES:

A. RJ PIPE AND FITTINGS MAY BE FACTORY RESTRAINED JOINTS IN PLACE OF MJ FITTINGS.